

McConnell, Kate

From: Brown, Ron
Sent: Tuesday, February 26, 2013 3:18 PM
To: McConnell, Kate
Subject: RE: SPEX-2012-0036 Brambleton Community Park New Condition Review (by Wed. Feb 27)
Attachments: Bramb Comm'ty Pk SPEX12-36 Cond2 022113rb.docx

Just a couple of suggested tweaks. Please call if you have any questions. Ron x0511

From: McConnell, Kate
Sent: Thursday, February 21, 2013 3:22 PM
To: Brown, Ron
Subject: SPEX-2012-0036 Brambleton Community Park New Condition Review (by Wed. Feb 27)

Ron,

At the PCPH on Tuesday, the Planning Commission added an additional condition (Condition 8) to the SPEX-2012-0036 Brambleton Community Park recommendation for approval. You previously reviewed and approved Conditions 1-7. Would you please review Condition 8 and provide your comments to me by the morning of Wednesday, February 27? This is a quick turnaround because the application is being double advertised (and I had to work out the language with Commissioner Salmon, Dana Malone, and the Applicant). Commissioner Salmon and the Applicant are in agreement with the draft of Condition 8.

Also, I will be out of the office tomorrow through next Tuesday, February 26.

Thanks for your help!
Kate

Kate A. McConnell, AICP
Planner - Land Use Review
Loudoun County Department of Planning
1 Harrison Street, S.E., 3rd Floor, MSC #62
P.O. Box 7000
Leesburg, Virginia 20177-7000

[O] 703.777.0246

[F] 703.777.0441

SPEX-2012-0036 Brambleton Community Park

Special Exception Application

Conditions of Approval

DRAFT

February 21, 2013

Staff recommends the following conditions of approval for **SPEX-2012-0036, Brambleton Community Park:**

1. **Substantial Conformance.** The development of the Special Exception use, lighted playing fields in the PD-H4 (Planned Development-Housing), administered as R-8 (Single Family Residential), zoning district, shall be in substantial conformance with Sheets 1 and 3 of 3 (herein referred to as the "Special Exception Plat") of the plan set entitled "Brambleton Community Park Special Exception" prepared by Patton Harris Rust & Associates, dated June 2012, revised through January 24, 2013 and the Revised 1993 Loudoun County Zoning Ordinance (the "Zoning Ordinance"). Approval of this application for an approximately 63.23-acre portion of an approximately 126.68 acre parcel identified as Tax Map Numbers /92////////34/, /91///7////26/, and /91///7////27/ (PIN#s 157-17-5653, 157-16-1062, and 157-25-2434 respectively) (the "Property") shall not relieve the Applicant or the owners of the Property from the obligation to comply with and conform to any other Zoning Ordinance, Codified Ordinance, or applicable regulatory requirement.
2. **Uses Permitted.** This Special Exception grants approval for a Lighted Playing Field use in the in the PD-H4 (Planned Development-Housing), administered as R-8 (Single Family Residential), zoning district as defined by the Zoning Ordinance and shown on the Special Exception Plat with the following conditions:
 - a. All lighting shall comply with the lighting standards of the Zoning Ordinance and shall be designed and constructed as follows to preclude light trespass onto adjoining properties, glare to passersby, skyglow, and deterioration of the nighttime environment: 1.) Playing field lighting shall be directed inward and downward toward the playing fields and away from public and private streets and adjacent properties, and shall incorporate a reflector technology system that minimizes glare and spillage on neighboring properties; 2.) Illumination levels for the playing fields shall be no greater than necessary for the intended purpose per the Loudoun County Parks, Recreation & Community Services ("PRCS") standards for rectangular fields and the outfield of the baseball/softball fields; 3.) Prior to approval of an Occupancy Permit, the Applicant shall demonstrate that the proposed lighting is in substantial conformance with the foot candles above ambient light at the property lot lines as demonstrated on the Special Exception Plat; and 4.) Light pole and light fixture typical details shall be shown on each site plan.
 - b. Playing field lighting shall only be used to light organized sport activities occurring on the playing fields identified on the Special Exception Plat. Playing field lighting shall be extinguished no later 10:00 p.m., except for occasional

planned tournaments when the lights shall be extinguished no later than 11:00 p.m., or within 15 minutes of the end of any sporting event, whichever occurs first. Playing field lighting shall not be illuminated between 11:00 pm and noon the following day. Security lighting may remain illuminated during overnight hours.

3. **Noise.** The Park shall be closed within 15 minutes of the conclusion of any organized sporting events requiring playing field lighting and extinguishment of the required lights.
4. **Pedestrian Facilities.** Prior to approval of an Occupancy Permit for the proposed lighted playing fields, the Applicant shall provide a "10' Asphalt Trail" along the east side of Belmont Ridge Road (Route 659) from north of the intersection with North Star Boulevard (Route 659 Relocated) to the northern terminus of the County-owned parcel as shown on the site plan, STPL-2010-0022, conditionally approved on August 23, 2012, and the Special Exception Plat.
5. **Sewage Disposal and Hand Washing Facilities.** Prior to approval of an Occupancy Permit for the proposed lighted playing fields, the Applicant shall obtain all required permits and approvals from the Loudoun County Division of Environmental Health for, and shall construct/install, an approved method of sewage disposal and water source for hand washing.
6. **Notification.** The Applicant shall post one sign in the eastern portion of the Brambleton Community Park at the southern parcel boundary and near the midpoint of the western "Football Field" as identified on the Special Exception Plat and adjacent to the single family attached development currently under construction (currently known as the Grand Townes at Brambleton (PIN # 158-47-5857)). Such sign shall be four (4) feet by eight (8) feet in size, shall be posted within one month of approval of this special exception application, and shall remain in place until installation of the western Football Field lighting is complete. Such sign shall include the following information: 1.) That field lighting will be installed on the Football Field, including a diagram showing the lighting design and pole heights; 2.) An estimated time of completion of the field lighting installation; and 3.) The park name and ownership and contact information.
7. **Western Football Field Lighting** – The Applicant shall install lighting on the western Football Field in a five (5) pole configuration as shown on the Special Exception Plat (poles F1, F2, F3, F4, and P1) to reduce the light intensity at the residential development lot line to the south.
8. **Screening and Buffering.** The Applicant shall plant a minimum of twenty (20) evergreen trees, each with a minimum height of six (6) feet, interspersed within the portion of the Tree Conservation Area beginning in the northeast corner of the Brambleton Community Park and extending 500 feet southward along the eastern property line adjacent to the Windermere Community Association property (PIN 157-19-1131) and shown on Sheet 2 of the Special Exception Plat. The evergreen species and planting arrangement shall be approved by the County Arborist in conjunction with the review of ~~with~~ the site plan or site plan amendment. The species shall be compatible with the site (soils, shade tolerance, slopes, etc.) and the trees

shall be planted in strategic locations that will achieve filtered screening in conjunction with the existing Tree Conservation Area. The evergreen trees shall be planted prior to approval of an Occupancy Permit for the proposed lighted playing fields.