



Loudoun County Health Department

P.O. Box 7000
Leesburg, VA 20177-7000



Environmental Health
Phone: 703 / 777-0234
Fax: 703 / 771-5023

Community Health
Phone: 703 / 777-0236
Fax: 703 / 771-5393

November 8, 2012

MEMORANDUM TO: Kate McConnell, Project Manager MSC # 60A
Department of Building and Development

FROM: Joseph E. Lock MSC # 68
Rural Section Supervisor *JEL*
Division Of Environmental Health

SUBJECT: SPEX 2012-0036, Brambleton Regional Park
PINs- 157161062, 157252434, 157175653

The above referenced project meets the requirements of Section 1245.10 of the LSDO for:

| | Yes | No | N/A |
|------------------------------|-------|-------|--------------|
| a. Proposed Drainfield Sites | _____ | _____ | <u> X </u> |
| b. Proposed Wells | _____ | _____ | <u> X </u> |

The locations on the plat, submitted by Patton Harris Rust & Associates dated September 10, 2012:

| | | | |
|--------------------------------------|-------|-------|--------------|
| a. Wells (existing and proposed) | _____ | _____ | <u> X </u> |
| b. Existing and Proposed Drainfields | _____ | _____ | <u> X </u> |

Health Department staff recommends: Approval__ Denial X
Approval with conditions_____

Items that are incorrect/deficient are listed on the attached page.

Attachments Yes X No _____

If further information or clarification on the above project is required, please contact me at (703)771-5800.

JEL/JDF/jel
C:BrambletonRegionalParkRef.Referral



ATTACHMENT

The properties listed do not have an approved means of sewage disposal or hand washing facilities. Pump and haul permits were approved by the Board of Supervisors in the past, however, if sewer and water facilities are within 300' of the properties, they must connect as required by the Board approval.